



- NOTE:**
1. ALL DIMENSIONS IN MILLIMETRES.
 2. REINFORCEMENT AS PER STRUCTURAL DESIGN WITH 65 MINIMUM COVER.
 3. INSIDE SURFACE OF SEWER MANHOLE AND UNDERSIDE OF ROOF TO HAVE EPOXY COATING, PVC LINING OR P.E. LINING **AS PER KAPITI COAST COUNCIL ENGINEER REQUIREMENTS.**
 4. WALL THICKNESS TO SUIT DN, MANUFACTURING AND INSTALLATION METHODS, APPLIED LOADS, AND DURABILITY DESIGN REQUIREMENTS, BUT TO BE 150 MIN OR 225 MIN IN AGGRESSIVE SOILS, HIGH WATER TABLE, AND SALINE ENVIRONMENTS.
 5. ALL CAST IN SITU BENCHING AND HAUNCHING TO BE 30 MPa CONCRETE AT A BATTER OF 1V:2.5H.
 6. **ALL MANHOLES DEEPER THAN 900 TO BENCHING SHALL BE FITTED WITH 20 Ø STEP IRONS.**
 7. **ALL LATERALS SHALL ENTER WHERE PRACTICAL AT SAME SOFFIT LEVEL AS MAIN INCOMING PIPE.**
 8. **DOUBLE FLEXIBLE JOINTS, TWO WITHIN 750 OF ANY MANHOLES, TO BE INSTALLED WITH SN16 PVC PIPES.**
 9. **ONE FLEXIBLE JOINT, ONE WITHIN 750 OF MANHOLES, TO BE INSTALLED WITH CONCRETE PIPES.**
 10. **STEPS TO BE ABOVE BENCHING WHERE POSSIBLE.**
 11. **ALL CONCRETE PIPES TO BE SAW CUT AND PIPE FACES COVERED WITH EPOXY RESIN / MORTAR.**
 12. **ANY SERVICES WITHIN NZTA ROAD CORRIDOR, MUST COMPLY WITH NZTA REQUIREMENTS.**

PIPE SIZE	MAXIMUM HORIZONTAL DEFLECTION AT CHAMBER	NOMINAL MANHOLE DIAMETER (SEE NOTE 5)	Ø 'C'
DN 375 - 450	45°	DN 1200	O.D. + 300
DN 500	45°	DN 1500, 1800	O.D. + 300
DN 750	45°	DN 1800	O.D. + 300

© Copyright Standards New Zealand 2011. Drawings from NZS 4404:2010 have been reproduced with permission from Standards New Zealand under Copyright Licence 000904. Refer to the complete Standard available for purchase from Standards New Zealand.
 KCDC AMENDMENTS TO NZS 4404:2010 SHOWN IN **BOLD.**



STANDARD DRAWINGS
MANHOLES
STORMWATER OR WASTEWATER (DN 375-750)

Drawn	S. TURKINGTON	Designed	J. SAXTON
Approved	M. COLE	Revision Date	OCTOBER 2015
Scale	NOT TO SCALE	Drawing No.	KCDC-CM-006
		Revision	R2