



STANDARD MANIFOLD INSTALLATION

TYPICAL WATER SERVICE PIPE AND WATER SERVICE VALVE MANIFOLD/TOBY

NOTE:

1. ALL DIMENSIONS IN MILLIMETRES.
2. SERVICE TO BE LAID TO THE CENTRE OF THE FRONT PROPERTY BOUNDARY AND AT RIGHT ANGLES TO STREET BOUNDARY.
3. THE INSTALLATION IS TO UTILISE THE STANDARD MANIFOLD METER SYSTEM WITH THE DOUBLE CHECK AND STRAINER IN THE BODY OF THE MANIFOLD.
4. FOR NEW ALOTMENTS A DUAL/RESTRICTED MANIFOLD SHALL BE INSTALLED. SEE KCDC WS 015.
5. NEW WATER SERVICE INSTALLATIONS OR ALTERED EXISTING WATER SERVICES SHALL BE FITTED WITH DUAL RESTRICTED MANIFOLDS FROM 2009.
6. 100mm COMPACTED AP40 OR CEMENT STABILIZED FILL UNDER BOX
7. WHEN MANIFOLD AND BOX ARE INSTALLED WITHIN A VEHICLE CROSSING - WATER PIPE TAILS MUST BE INSTALLED FOR PLUMBER TO ACCESS



STANDARD DETAILS
WATER SERVICE CONNECTIONS TYPICAL CONNECTIONS WITH MANIFOLD

Drawn	Designed	
A. KOCHAR	J. SAXTON	
Approved	Revision Date	
M. COLE	APRIL 2021	
Scale	Drawing No.	Revision
NOT TO SCALE	KCDC-WS-011	R4