



**50mm RESIDENTIAL CONNECTION REQUIRING
STRAINER, METER & DOUBLE CHECK VALVE**

NOTE:

1. ALL DIMENSIONS IN MILLIMETRES.
 2. SERVICE TO BE LAID TO THE CENTRE OF THE FRONT PROPERTY BOUNDARY AND AT RIGHT ANGLES TO STREET BOUNDARY.
 3. FOR 40-50mm RESIDENTIAL / LOW RISK SUPPLY IN R.O.W INSTALLATIONS ONLY.
 4. DOUBLE CHECK VALVE. PLACE AS CLOSE AS POSSIBLE TO BOUNDARY OTHERWISE IN PRIVATE PROPERTY (TOP ENTRY ONLY) TO BE USED FOR LOW HAZARD RISK INSTALLATIONS ONLY.
- NOTE: ABOVE GROUND RPZ MAY BE DIRECTED BY COUNCIL. REFER SHEET WS-012



STANDARD DETAILS
WATER SERVICE CONNECTIONS
TYPICAL ROW & RIDERMAIN CONNECTIONS

Drawn	Designed	
A. KOCHAR	J. SAXTON	
Approved	Revision Date	
M. COLE	MAY 2021	
Scale	Drawing No.	Revision
NOT TO SCALE	KCDC-WS-015	R6