

# **National Code of Practice for Utilities' Access to Transport Corridors**

**Kāpiti Coast District Council local conditions**



## **Schedule B – template for reasonable conditions**

### **Attachment I – Local Conditions – Kapiti Coast District Council**

#### **2.4.1 Maintenance of Above Ground Utility Structures: - add new sub-clause (o)**

It is considered that a reasonable time to remove graffiti is within 14 days of notification.

#### **5.2.1 Locating Existing Underground Utilities 1. (a) add new sub-clause**

Council requires Utility Operators to apply the following procedure:

- Use a minimum amount of paint when marking out in these areas.
- Use only water based paints.
- If the markings are still visible four weeks after the completion of works, utility operators are to remove markings from Council's infrastructure (particularly footpaths) upon reinstatement/completion of works. This is particular concern within the high pedestrian/cycling areas and retail areas.

#### **5.3.4 Hours of Work – add new sub-clause (c)**

##### **Restrictions to Working Hours**

Unless the Corridor Manager has agreed that the benefits to the public good outweigh the disadvantages, hours of work shall be restricted as detailed below.

##### **(i) Residential Areas**

Construction work shall be restricted to between 8:00 am and 6pm Monday to Friday, 7:30am to 6:00pm on Saturday. Noisy construction work is not permitted at any time on Sundays or public holidays.

## Network Hierarchy

### Kapiti Coast District Council – Central; Business/Retail & Major & Centre Connector Routes works within the carriageway:

“No works shall take place between 7.30am and 9am, nor 3pm and 6pm Monday to Friday. At other times between 6am and 7pm Monday to Saturday, a minimum of one lane each way shall be maintained.” No work shall take place in these areas in the three week period immediately preceding, or within the two (2) week period following Christmas day

### Kapiti Coast District Council – Major & Centre Connector Routes works within the carriageway:

No.	Street	Section
1	Mill Road	Entire
2	Riverbank Road	Entire
3	Otaki River Walkway	Entire
4	Otaki Forks Road	Entire
5	Te Moana Road	To Rauparara Street
6	Elizabeth Street	From Seddon Street east
7	Waikanae River	Walkway
8	Reikorangi Road	Entire
9	Akatarawa Road	To summit
10	Raumati Road	Entire
11	Ihakara Street	Entire
12	Wharemauku Road	Entire
13	Poplar Avenue	Entire
14	Kapiti Coast Cycleway	Walkway
15	Kapiti Road	S H 1 to Rimu Road
16	Rimu Road	Entire
17	Main Street, Otaki	Entire
18	Matene Street	Entire
19	Aotaki Street	Rangatira Road to Main Street
20	Rangatira Road	Entire
21	Rangiuru Road	Entire
22	Beach Road	S H 1 to Wellington Road
23	Raumati Road	Hillcrest Road to Rosetta Road
24	Rosetta Road	front of Raumati Gardens - open space
25	Marae Lane	Entire
26	Ngaio Road	Omahi Street to S H 1
27	Elizabeth Street	S H 1 to seddon Street
28	Pehi Kupe Street	Entire
29	Howell Road	Entire
30	Maclean Street	Entire
31	Seaview Road	Howell Road to Maclean Street

**Kapiti Coast District Council - Local Community Connector works within the carriageway:**

<b>No.</b>	<b>Street</b>	<b>Section</b>
53	Tasman Road	Entire
54	Rangiuru Road	Entire
55	Aotaki Street	Entire
56	Te Horo Beach Road	Entire
57	Old Hautere Road	Entire
58	Morrison Road	Entire
59	Peka Peka Road	Entire
60	Paetawa Road	Entire
61	Rutherford Drive	Entire
62	Te Moana Road	from Rauparaha Street
63	Waimea Road	Te Moana to Weggery Drive
64	Weggery Drive	Entire
65	Queens Road	to Eruni Street
66	Eruini Street	Entire
67	Tutere Street	Eruini to Te Moana Road
68	Park Avenue	Entire
69	Ngarara Road	From Te Moana to Rimu Street
70	Rimu Street	Entire
71	Miro Street	Entire
72	Ngaio Road	Omahi Street to Miro Street
73	Wellington Road	Entire
74	Hillcrest Road	Entire
75	Menin Road	Entire
76	Te Roto Drive	Entire
77	Guildford Drive	Entire

To work within the time periods referred to above, the Corridor Manager's written permission is required. As part of the permission, the Contractor is required, in conjunction with the Corridor Manager, to consult affected business owners.

Where work is being undertaken adjacent to, and is likely to impact upon, a residential area, the residential area restrictions shall apply.

**(iii) Major, Centre and Local Community Connector Routes – Kapiti Coast District Council  
Primary Arterial – Kapiti Coast District Council**

Conditions are covered in "Attachment II – Specific conditions" below.

Where work is being undertaken adjacent to, and is likely to impact upon, a residential area, the residential area restrictions shall apply.

**5.6.4 Specific Requirements for Different Surface Types**

Grass seed mixture shall be 85% drought tolerant, amenity turf rye grass and 15% red fescue – other mixtures may only be used on the specific approval of the Council.

## Attachment II – Specific Conditions - Kapiti Coast District Council

### Minimum Cover to Utility Services

Pipe services shall be laid within the following ranges of cover unless sound engineering reasons can be provided for alternative covers in which case supporting analysis shall be provided to show special pipe standards or other protection.

Depths of Services		
Type	Cover to top of pipe barrel	
	Min [mm]	Max [mm]
Power	450	900
Telecommunication	450	750
Other information cabling	450	750
Gas	600	900
Water mains in carriageway	750	1200
Water mains in berms and footpaths	750	1200
Rider mains and service pipes in carriageway	600	800
Rider mains and service pipes in berms and footpaths	600	800
Gravity wastewater and stormwater	900	
Pressure main – wastewater and stormwater	750	1200
Wastewater and stormwater service laterals at Lot boundary	600	1200